## SUPPLIER DECLARATION OF CONFORMITY (SDoC) In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number: EN14-2015		
Issuer details		
Name (of New Zealand manufacturer or importer):		Contact Address:
Transformer Specialties Ltd		6 Grivelle Street Kumeu, Auckland 0841 New Zealand
00.440.7000		
reichnoric.		
New Zealand Company No. (if applicable): 28311		
Email Address: admin@tsltransformers.co.nz		
Medium Risk Article - Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):		
Product code EN14  Description Enclosed IP67, single phase, safety isolating transformer  Specification 230vac / 12vac, 50~60Hz  Power rating Brand TSLtransformers		
The Medium Risk Article listed above, fully complies:		
With cited standard(s), as listed:		
Standard number and issue year: ASNZS 6155	8.1:2008	Standard number and issue year: ASNZS 61558.2.6:2009
Edition / Amendment status: Ed 2.0		Edition / Amendment status: Ed 2.0
Standard title:		Standard title:
Safety of power transformers, power supply units and similar.  Part 1. General requirements and tests		Part 2. Particular requirements for safety isolating transformers for general use.
AS/NZS ZZ modified Yes No N/A		AS/NZS ZZ modified Yes No No N/A
AS/NZS ZZ IIIOdilled Tes No N/A AS/NZS ZZ IIIOdilled Tes No N/A		
OR Complies with the Conformity Cooperation Agreement <sup>5</sup> Yes No		
Names and addresses of any testing organisation or body		
Name(s): Transformer Specialties Ltd Address(es): 6 (		6 Grivelle Street
		Kumeu, Auckland 0841
		New Zealand
Name(s):	Address(es):	
Reference to relevant test reports/certification and the issue date that show how compliance is achieved		
Standard(s) or document(s) used, to show how compliance with cited standard is achieved:		Report Certification or Document Issue dates(s): reference N°(s):
ASNZS61558 (Part 1 & Part 2.6)		Redacted from ASNZS 3108 01/07/2005
,		Redacted from ASNZS 61558.1 01/07/2008
		Redacted from ASNZS 61558.2 01/07/2009
		Last verified 01/07/2015
Reference to any management quality system involved: Proprietary quality assurance system		
Additional information: 100% of batch routine tests performed		
Declaration (signed for and on behalf of)		
Name and position as authorized by the issuer:		Signature:
Karl Canham, Design Engineer		
Issuer Identification (as affixed to the article):		
ASNZS / IEC 61558		Date:
		01.07.2015