SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number: EN35-2015 Issuer details Name (of New Zealand manufacturer or importer): Contact Address: Transformer Specialties Ltd 6 Grivelle Street Telephone: 09 412 7280 New Zealand Company No. (if applicable): 28311 Email Address: admin@tisltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50-60Hz Power rating 200V-A arand TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Standard number and issue year: ASNZS 61558.1:2008 Standard Itile: Standard number and issue year: Safety of power transformers, power supply units and similar. Part 12. Particular requirements for isolating transformers Part 1. General requirements and tests ASINZS ZZ modified Yes No NA Context (Street Kumeu, Auckland 0841 New Zealand Name(s): Transformer Specialties Ltd </th
Name (of New Zealand manufacturer or importer): Contact Address: Transformer Specialties Ltd 6 Grivelle Street Kumeu, Auckland 0841 New Zealand New Zealand Company No. (if applicable): 28311 Email Address: admin@tsltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Yower rating 200V A 200Vac Arand TSLtransformers The Medium Risk Article listed above, fully complies: Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Standard title: Standard title: Standard
Transformer Specialties Ltd 6 Grivelle Street Telephone: 09 412 7280 New Zealand Company No. (# applicable); 28311 Email Address: admin@tsltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable); Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Ower rating 200V/A 3rand TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Standard number and issue year: ASNZS 61558.2:4:2009 Edition / Amendment status: Ed 2.0 Standard tite: Standard tite: Condities with the Conformity Cooperation Agreement* Yes No Name(s): Transformer Specialties Ltd
Telephone: 09 412 7280 New Zealand Company No. (If applicable): 28311 Email Address: admin@tsltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Power rating 200V A Bower rating 200V A Standard number and issue year: ASNZS 61558.1:2008 Standard number and issue year: ASNZS 61558.2:4:2009 Edition / Amendment status: Ed 2.0 Standard tille: Standard tille: Safety of power transformers, power supply units and similar. Part 2. Particular requirements for isolating transformers for general use. Part 1. General requirements and tests No NA ASNZS ZZ modified Yes No Name(s): Transformer Specialties Ltd Address(es): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurm
Telephone: [U9 412 7280] New Zealand Company No. (If applicable): [28311] Email Address: admin@tsltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Power rating 200V.A 3rand TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard number and issue year: ASNZS 61558.2.4:2009 Editor / Amendment status: Ed 2.0 Standard title: Standard number and issue year: SASNZS ZZ modified Yes No No NA AS/NZS ZZ modified Yes No No NA Part 1. General requirements and tests No Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s):
Email Address: admin@tsltransformers.co.nz Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description 400vac / 230vac, 50~60Hz Power rating 200V.A Brand TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Standard title: Standard title: Standard title: Standard title: Standard title: Part 1. General requirements and tests AS/NZS ZZ modified Yes Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Name(s): Address(es): Barnet Address(es): Barnet Address(es): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): Barnet is the ports/certification and the issu
Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable): Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Power rating 200V.A Standard TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Standard title: Standard title: Standard title: Part 2. Particular requirements for isolating transformers for general use. Part 1. General requirements and tests AS/NZS ZZ modified ASINZS ZZ modified Yes No Name(s): Iransformer Specialties Ltd Address(es): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 Name(s): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 Name(s): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 Name(s): Address(es): 6 Grivelle Street Kumeu, Auck
Product code EN35 Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50~60Hz Power rating 200V.A 3rand TSLtransformers The Medium Risk Article listed above, fully complies: With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.2.4:2009 Edition / Amendment status: Ed 2.0 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Standard title: Standard title: Safety of power transformers, power supply units and similar. Part 1. General requirements and tests Part 2. Particular requirements for isolating transformers for general use. AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Ni/A Mi/A Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand New Zealand Name(s): Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand New Zealand
Description Enclosed IP67, single phase, isolating transformer Specification 400vac / 230vac, 50-60Hz 200V/A 200V/A Standard time Standard time and issue year: ASNZS 61558.1:2008 Standard number and issue year: Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Safety of power transformers, power supply units and similar. Part 2. Particular requirements for isolating transformers for general use. Part 1. General requirements and tests No N/A AS/NZS ZZ modified Yes No Names and addresses of any testing organisation or body No Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 Name(s): Address(es): 6 Grivelle Street
With cited standard(s), as listed: Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Safety of power transformers, power supply units and similar. Part 1. General requirements and tests AS/NZS ZZ modified Yes No OR Complies with the Conformity Cooperation Agreement ⁶ Yes No Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand Name(s): Address(es): 6 Grivelle Street Kurmeu, Auckland 0841 New Zealand
Standard number and issue year: ASNZS 61558.1:2008 Edition / Amendment status: Ed 2.0 Standard title: Standard title: Safety of power transformers, power supply units and similar. Part 1. General requirements and tests AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No Name(s): Transformer Specialties Ltd Address(es): Address(es): Address(es): C G Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): Address(es): Address(es):
Edition / Amendment status: Ed 2.0 Standard title: Standard title: Safety of power transformers, power supply units and similar. Part 2. Particular requirements for isolating transformers for general use. Part 1. General requirements and tests Part 2. Particular requirements for isolating transformers for general use. AS/NZS ZZ modified Yes No N/A OR Complies with the Conformity Cooperation Agreement ⁶ Yes No N/A Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): Edition / Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Reference to relevant test reports/certification and the issue date that show how compliance is achieved Address(es):
Standard title: Safety of power transformers, power supply units and similar. Part 1. General requirements and tests AS/NZS ZZ modified Yes No No NA AS/NZS ZZ modified Yes No No Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): Address(es): Address(es): Address(es): Beference to relevant test reports/certification and the issue date that show how compliance is achieved
Safety of power transformers, power supply units and similar. Part 2. Particular requirements for isolating transformers for general use. Part 1. General requirements and tests AS/NZS ZZ modified Yes No NA AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No OR Complies with the Conformity Cooperation Agreement ⁵ Yes No Names Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): E Grivele Street Kumeu, Auckland 0841 New Zealand New Zealand
similar. Part 1. General requirements and tests AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No OR Complies with the Conformity Cooperation Agreement ⁵ Yes No Name(s): Transformer Specialties Ltd Address(es): Address(es): Address(es): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No N/A OR Complies with the Conformity Cooperation Agreement ⁵ Yes No No Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): Address(es): Address(es): Address(es): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
OR Complies with the Conformity Cooperation Agreement ⁵ Yes Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es):
Names and addresses of any testing organisation or body Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Kumeu, Auckland 0841 New Zealand Name(s): Address(es): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
Name(s): Transformer Specialties Ltd Address(es): 6 Grivelle Street Name(s): Address(es): Address(es): Name(s): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
Name(s): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
Name(s): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
Name(s): Address(es): Reference to relevant test reports/certification and the issue date that show how compliance is achieved
Reference to relevant test reports/certification and the issue date that show how compliance is achieved
O(t) = O(t) +
Standard(s) or document(s) used, to show how compliance Report Certification or Document Issue dates(s): with cited standard is achieved: reference N°(s):
ASNZS61558 (Part 1 & Part 2.4) Redacted from ASNZS 3108 01/07/2005
Redacted from ASNZS 61558.1 01/07/2008 Redacted from ASNZS 61558.2 01/11/2012
Last verified 01/07/2015
Reference to any management quality system involved: Proprietary quality assurance system
Additional information: 100% of batch routine tests performed
Declaration (signed for and on behalf of)
Name and position as authorized by the issuer: Signature:
Karl Canham, Design Engineer
Issuer Identification (as affixed to the article):