SUPPLIER DECLARATION OF CONFORMITY (SDoC) In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number:	ISA1150575-2015	
Issuer details		
Name (of New Zealand manufacturer	or importer):	Contact Address:
Transformer Specialties Ltd		6 Grivelle Street Kumeu, Auckland 0841 New Zealand
Telephone: 09 412 7280		
New Zealand Company No. (if applicable): 28311		
Email Address: admin@tsltransformers.co.nz		7
daming to transformers.		
Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):		
Product code ISA1150575 Description In-line power supply, single phase, isolating transformer Specification 230vac / 115vac, 50~60Hz Power rating Product code ISA1150575 In-line power supply, single phase, isolating transformer 230vac / 115vac, 50~60Hz 575V.A Brand TSLtransformers		
The Medium Risk Article listed above, fully complies:		
With cited standard(s), as listed:		
Standard number and issue year:	ASNZS 61558.1:2008	Standard number and issue year: ASNZS 61558.2.4:2009
Edition / Amendment status:	Ed 2.0	Edition / Amendment status: Ed 2.0
Standard title:		Standard title:
Safety of power transformers, power supply units and similar. Part 2. Particular requirements for isolating transformers for general use.		Part 2. Particular requirements for isolating transformers for general use.
AS/NZS ZZ modified Yes	No N/A	AS/NZS ZZ modified Yes No No N/A
OR Complies with the Conformity Cooperation Agreement ⁵ Yes No		
Names and addresses of any testing organisation or body		
Name(s): Transformer Specia	alties I td Address(es):	6 Grivelle Street
		Kumeu, Auckland 0841
		New Zealand
Name(s):	Address(es):	
Reference to relevant test reports/certification and the issue date that show how compliance is achieved		
Standard(s) or document(s) used, to show how compliance Report Certification or Document Issue dates(s):		
with cited standard is achieved:		reference N°(s):
ASNZS61558 (Part 1 & Part 2.4)		Redacted from ASNZS 3108 Redacted from ASNZS 61558.1 Redacted from ASNZS 61558.2 Last verified 01/07/2005 01/07/2008 01/11/2012 01/07/2015
Reference to any management quality system involved: Proprietary quality assurance system		
Additional information: 100% of batch routine tests performed		
Declaration (signed for and on behalf of)		
Name and position as authorized by the issuer:		Signature:
		A / / /
Karl Canham, Design Engineer Issuer Identification (as affixed to the article):		
		The Carl
		Date:
		01.07.2015