SUPPLIER DECLARATION OF CONFORMITY (SDoC) In accordance with ISO/IEC 17050-1:2004

SDoC Ide	ntification Number:	PN57-201	5			
Issuer details						
Name (of New Zealand manufacturer or importer): Transformer Specialties Ltd				Contact Address: 6 Grivelle Street		
				Kumeu, Auckland 0841		
				New Zealand		
New Zealand Company No. (if applicable): 28311 Email Address: admin@tsltransformers.co.nz						
Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):						
Product codePN57DescriptionEnclosed IP40, single phase, safety isolating transformerSpecification230vac / 12vac or 24v, 50~60HzPower rating300V.ABrandTSLtransformers						
The Medium Risk Article listed above, fully complies:						
With cited	standard(s), as listed:					
Standard n	Standard number and issue year: ASNZS 61558.1:2008			Standard number and issue year: ASNZS 61558.2.6:2009		
Edition / Amendment status: Ed 2.0				Edition / Amendment status: Ed 2.0		
Standard title: Safety of power transformers, power supply units and				Standard title: Part 2. Particular requirements for safety isolating		
similar.				transformers for general use.		
Part 1. General requirements and tests						
AS/NZS ZZ modified Yes No N/A AS/NZS ZZ modified Yes No N/A Image: Comparison of the second sec						
OR Complies with the Conformity Cooperation Agreement ⁵ Yes No						
Names and addresses of any testing organisation or body						
Name(s):	s): Transformer Specialties Ltd Address(es):			6 Grivelle Street Kumeu, Auckland 0841 New Zealand		
Name(s):			Address(es):			
Reference to relevant test reports/certification and the issue date that show how compliance is achieved						
Standard(s) or document(s) used, to show how compliance Report Certification or Document Issue dates(s):						
with cited standard is achieved: ASNZS61558				Redacted from ASNZS 3108 01/07/2005 Redacted from ASNZS 61558.1 01/07/2008		
				Redacted from ASNZS 61558.201/07/2009Last verified01/07/2015		
Reference to any management quality system involved: Proprietary quality assurance system						
Additional information ⁶ : 100% of batch routine tests performed						
Declaration (signed for and on behalf of)						
Name and position as authorized by the issuer: Signature:						
Karl Canham, Design Engineer				A////		
Issuer Identification (as affixed to the article):						
				It Cat		
ASNZS / IEC 61558				Date:		
				01.07.2015		
1						