

# SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number: PX67-2015

## Issuer details

Name (of New Zealand manufacturer or importer):

Transformer Specialties Ltd

Telephone: 09 412 7280

New Zealand Company No. (if applicable): 28311

Email Address: admin@tsltransformers.co.nz

Contact Address:

6 Grivelle Street  
Kumeu, Auckland 0841  
New Zealand

## Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Product code PX67  
Description Open frame, single phase, safety isolating transformer  
Specification 400vac / 12vac or 24v, 50~60Hz  
Power rating 50V.A  
Brand TSLtransformers

## The Medium Risk Article listed above, fully complies:

### With cited standard(s), as listed:

Standard number and issue year: ASNZS 61558.1:2008

Edition / Amendment status: Ed 2.0

Standard title:

Safety of power transformers, power supply units and similar.  
Part 1. General requirements and tests

Standard number and issue year: ASNZS 61558.2.6:2009

Edition / Amendment status: Ed 2.0

Standard title:

Part 2. Particular requirements for safety isolating transformers for general use.

AS/NZS ZZ modified Yes  No  N/A

AS/NZS ZZ modified Yes  No  N/A

OR Complies with the Conformity Cooperation Agreement<sup>5</sup> Yes  No

## Names and addresses of any testing organisation or body

Name(s): Transformer Specialties Ltd

Address(es): 6 Grivelle Street  
Kumeu, Auckland 0841  
New Zealand

Name(s):

Address(es):

## Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved:

ASNZS61558

Report Certification or Document reference N°(s):

Redacted from ASNZS 3108  
Redacted from ASNZS 61558.1  
Redacted from ASNZS 61558.2  
Last verified

Issue dates(s):

01/07/2005  
01/07/2008  
01/07/2009  
01/07/2015

Reference to any management quality system involved: Proprietary quality assurance system

Additional information<sup>6</sup>: 100% of batch routine tests performed

## Declaration (signed for and on behalf of)

Name and position as authorized by the issuer:

Karl Canham, Design Engineer

Issuer Identification (as affixed to the article):



Signature:

A handwritten signature in blue ink, appearing to read 'Karl Canham'.

Date:

01.07.2015